


Project X Upgrade Options for 4 MW at 8 GeV



Sergei Nagaitsev

June 28, 2011

Reference Design






Reference Design Capabilities

- 3 GeV CW superconducting H- linac with 1 mA average beam current.
 - 3 MW beam power at 3 GeV
 - Flexible provision for variable beam structures to multiple users
 - CW at time scales $>1 \mu\text{sec}$, 15% DF at $<1 \mu\text{sec}$
 - Supports rare processes programs at 3 GeV
 - Provision for 1 GeV extraction for nuclear energy program
- 3-8 GeV pulsed linac capable of delivering 340 kW at 8 GeV
 - Supports the neutrino program
 - Establishes a path toward a muon based facility
- Upgrades to the Recycler and Main Injector to provide ≥ 2 MW to the neutrino production target at 60-120 GeV.


Reference Design

Provisional Siting




Reference design: accelerator scope

- Warm cw front end 162.5 MHz, 5 mA (H- ion source, RFQ, MEBT, chopper)
- 3-GeV cw SCRF linac (325, 650 MHz), 1-mA ave. beam current
- Transverse beam splitter for 3-GeV experiments
- 3-8 GeV: pulsed linac (5% duty cycle), 1.3 GHz
- Recycler and MI upgrades
- Various beam transport lines




Reference design: cost distribution




Linac beam current

- Linac beam current has a periodic time structure (at 10 Hz) with two major components.




Chopping for injection

- RF frequency at injection into the Recycler : ~ 50 MHz
- Chopper needs to provide a kicker gap (~ 200 ns per $11\ \mu\text{s}$) and needs to remove bunches that fall into “wrong” phase of ring rf voltage.
 - 50% of bunches are removed (ion source at 2 mA)
 - 80% of bunches are removed (ion source at 5 mA)






Ion source: TRIUMF-type H- DC ion source



TRIUMF Type DC Volume-Cusp H⁻ Ion Source
Model: IS-15mA-30keV-H⁻



Dehnel - Particle Accelerator Components and Engineering, Inc.

Delivered to LBNL: June 2011

Model: IS-15mA-30keV-H⁻ SPECIFICATIONS

Ion Source Specifications

Particle Type:

H⁻

Beam Current:

0 to 15 mA

Beam Kinetic Energy:

20 to 30 keV

Normalized 4rms Emittance:

<1 mm²mrad

Beam Purity:

>98%

Filament Lifetime:

>350 hours at peak current


Beam Current Stability:

±3% over 24 hours

Proposed LEBT configuration

Two ion sources, selected by a 20 degree magnet

Solenoid focusing
after the ion source
in front of the RFQ



- LEBT will have a chopper to provide gaps of >100 ns





RFQ (162.5 MHz)

Input energy	30 keV	
Output energy	2.1 MeV	
Vane-vane voltage	58 kV	
Length	446 cm	
S'Fish power/cm	120 watts	
Total Power	<100 kW	
Wall Power Density	0.6 w/cm ²	


I (mA)	ex	ey	ez	keV-nsec	transm	Data Set
0	0.01178	0.01173	0.04047	1.27	98.9	30.05
1	0.01205	0.01260	0.03129	0.98	97.8	30.01
2	0.01305	0.01297	0.02549	0.80	96.4	30.05
3	0.01275	0.10264	0.02051	0.64	95.8	30.05
4	0.01192	0.10224	0.01939	0.61	95.5	30.05
5	0.01115	0.01190	0.01989	0.62	95.5	30.05
7	0.01166	0.01179	0.02404	0.75	95.5	30.05
10	0.01859	0.01806	0.02883	0.90	95.3	30.10

MEBT design: 5 mA at 162.5 MHz beam

TraceWin - CEA/DSM/Irfu/SACM




325 MHz warm bunching cavities




$$\epsilon_{\perp} = 0.25 \pi \cdot \mu\text{m}; \quad \epsilon_{z,n} = 0.3 \pi \cdot \mu\text{m}$$

SRF Linac Technology Map



Section	Freq	Energy (MeV)	Cav/mag/CM	Type
SSR0 ($\beta_G=0.11$)	325	2.5-10	18 /18/1	SSR, solenoid
SSR1 ($\beta_G=0.22$)	325	10-42	20/20/ 2	SSR, solenoid
SSR2 ($\beta_G=0.4$)	325	42-160	40/20/4	SSR, solenoid
LB 650 ($\beta_G=0.61$)	650	160-460	36 /24/6	5-cell elliptical, doublet
HB 650 ($\beta_G=0.9$)	650	460-3000	160/40/20	5-cell elliptical, doublet
ILC 1.3 ($\beta_G=1.0$)	1300	3000-8000	224 /28 /28	9-cell elliptical, quad



325 MHz spoke cavity families



SSR0 – design, prototyping



SSR1 – prototyping, testing




SSR2 - design

Parameters of the single-spoke cavities

cavity type	β_G	Freq MHz	$U_{\text{acc, max}}$ MeV	E_{max} MV/m	B_{max} mT	R/Q, Ω	G, Ω	$*Q_{0,2K} \times 10^9$	$P_{\text{max},2K}$ W
SSR0	$\beta=0.114$	325	0.6	32	39	108	50	6.5	0.5
SSR1	$\beta=0.215$	325	1.47	28	43	242	84	11.0	0.8
SSR2	$\beta=0.42$	325	3.34	32	60	292	109	13.0	2.9




650 MHz cavities



Parameter		LE650	HE650
β_{geom}		0.61	0.9
R/Q	Ohm	378	638
G-factor, Ohm		191	255
Max. Gain/cavity (on crest)	MeV	11.7	19.3
Acc. Gradient	MV/m	16.6	18.7
Max surf. electric field	MV/m	37.5	37.3
Max surf. magnetic field,	mT	70	70
$Q_0 @ 2^\circ K$	$\times 10^{10}$	1.5	2.0
$P_{2K} \text{ max}$	[W]	24	29

Energy Gain per Cavity




- Single cavity per power source
 - Solid State, IOT



3 GeV CW Linac


Cryogenic Losses per Cavity



- ~42 kW cryogenic power at 4.5 K equivalent


3 – 8 GeV acceleration

- Pulsed linac based on the ILC technology
 - 1.3 GHz, 25 MV/m gradient, $\leq 5\%$ duty cycle
 - considering 8-30 ms pulse length
 - ~ 250 cavities (28 ILC-type cryomodules) needed.
 - Simple FODO lattice
 - 1 Klystron per 2 CM's





Cavity Energy Gain





Proposed power upgrade for Project X linac

- To attain 4 MW at 8 GeV we propose:
 - to increase the beam current during the injection pulse to 5 mA (10 mA peak);
 - to increase the rep. rate to 15 Hz;
 - to increase the beam pulse length to 6.7 ms (10% duty cycle).



Impact of upgrade on linac subsystems

- Front End: no impact (it is already being designed for 10 mA ave.)
- CW linac: the impact depends principally on the demand for beam power at 3 GeV.
 - Worst-case scenario: 10% duty cycle – 5 mA for MC/NF and 90% duty cycle – 1 mA
- Pulsed linac: the impact is well understood
 - More rf power (because of higher current);
 - Upgrade power couplers (because of higher current);
 - More cryo capacity (because of a longer pulse);
- Conventional facilities
 - more water cooling;
 - more room for Klystrons;
 - the impact is not fully understood yet.




Pulsed linac (1.3 GHz)

	Reference Design Report (RDR)	Upgrade for Muon Collider
Rep rate, [Hz]	10	15
RF period, [msec]	100	67
Duty cycle, [%]	4.3	10
Fill time ,[msec]	3.0	1
Beam pulse, [msec]	4.3	6.7
Beam current, [mA]	1	5
4.5 K Equivalent heat load, [kW]	8	13
Normalized cryo plant cost, [-]	1	1.3

Linac parameters	
Eacc, [MV/m]	25
Q ₀ , [-]	1.50E+10
Beam Energy, [GeV]	8
Number of Cavities	224
Number of Cryomodules	28

- Average rf coupler power:
 - RDR: 2 kW
 - Upgrade: 15 kW
- Pulsed rf power:
 - Upgrade: 125 kW per cavity (~7.5 ms at 15 Hz)
 - such Klystrons exist (e.g. Philips YK1240)

CW Linac



- With present technology: rf power to beam power is not 100% efficient. Some power will be reflected and transferred to heat.
- Cryogenic power remains the same in RDR

RF power requirements at 650 MHz

$f = 650 \text{ MHz}$;
 $\delta f = 18 \text{ Hz}$ - microphonics;
 $(r/Q) = 640 \text{ Ohms}$;
 $I_{CW} = 1 \text{ mA}$ - DC current;
 $I_{pulse} = 5 \text{ mA}$ - pulse current
 $\varphi = -10^\circ$ - synch. phase;
 $V = 17.5 \text{ MeV}$ - gain/cavity;
 $= 7.3 \text{ msec}$ - pulse width;
 $f_{rep} = 15 \text{ Hz}$;
 $N = 160$ – number of cavities
16% overhead for control and losses in the line


$$Q_{load}(1\text{mA}) = 1.5 \times 10^7$$

$$Q_{load}(2\text{mA}) = 1.1 \times 10^7$$

$$P_{CW}(1\text{mA}) = 28 \text{ kW}$$

$$P_{CW}(2\text{mA}) = 30 \text{ kW}$$

$$P_{total} = N(P_{CW}(1-f_{rep}\tau) + P_{pulse}f_{rep}\tau)$$





Summary

- A plausible upgrade path to 4 MW at 8 GeV for Project X exists and includes:
 - increasing the beam current during the injection pulse to 5 mA (10 mA peak);
 - increasing the rep. rate to 15 Hz;
 - increasing the beam pulse length to 6.7 ms (10% duty cycle).
- Such an upgrade would reuse > 75% of RDR cost.